

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7770-1568:100 Page 1 of 1

CATEGORY: Valves/Switches

LISTEE: Central *Grooved Piping Products, 1550 Valley center Parkway, Bethlem, PA 18017
Contact: Phil D'Annibale (610) 882-4390

DESIGN: Model 590 series check valves. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Working pressure: 300 Psi
Sizes: 2-1/2", 3", 4", 6"

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as swing type check valves for use with fire sprinkler systems. For horizontal and vertical position.

NOTE: Formerly 7765-0675:100 & 7770-0675:100

*Rev. 10-04-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager